TMS-Archive Retrieval

TMS-USI Menu/Get TMS Archive Data – **USI sends the archive data line by line until complete. Archive file is saved in the Arch_Data sub-folder using the name specified in the General Parameters. The archive file is a space delimited, spread sheet ready file.**

Status Line: TMS Display Lower Left Area



General Parameters

Probe Parameters (1 to N)

Archive Data

```
TMS0001 007 Kelly Cresent Company  Indianapolis
Archive_KellyCresent.atx 15 5 30 0 0 1
0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0
10
8C00000006CE4310 +000.0 +010.0 +040.0 5 Probe # 01..8C00000006CE4310 01 1 000
1400000006CC7C10 +000.0 +010.0 +040.0 5 Probe # 02..1400000006CC7C10 02 1 000
F800000006CA9F10 +000.0 +010.0 +040.0 5 Probe # 03..F800000006CA9F10 03 1 000
F10000000A28DE10 +000.0 +010.0 +040.0 5 Probe # 04..F10000000A28DE10 04 1 000
2F00000006CC1710 +000.0 +010.0 +040.0 5 Probe # 05..2F00000006CC1710 05 1 000
0300000006CD4D10 +000.0 +010.0 +040.0 5 Probe # 06..0300000006CD4D10 06 1 000
4100000006CE2710 +000.0 +010.0 +040.0 5 Probe # 07..4100000006CE2710 07 1 000
F600000006CAE610 +000.0 +010.0 +040.0 5 Probe # 08..F600000006CAE610 08 1 000
0E00000006CE8910 +000.0 +010.0 +040.0 5 Probe # 09..0E00000006CE8910 09 1 000
CF00000006CCC810 +000.0 +010.0 +040.0 5 Probe # 10..CF00000006CCC810 10 1 000
03-23-2005 10:50:00 +071.1 1 +072.5 1 +072.7 1 +071.0 1 +071.1 1 +071.8 1 +072.3 1 +074.7 1 +072.5 1 +073.3 1
03-23-2005 10:55:00 +071.2 1 +072.5 1 +072.8 1 +071.1 1 +071.4 1 +072.0 1 +072.5 1 +074.7 1 +072.9 1 +073.6 1
03-23-2005 11:00:00 +071.3 1 +072.5 1 +072.9 1 +071.2 1 +071.5 1 +072.1 1 +072.7 1 +074.9 1 +072.9 1 +073.6 1
03-23-2005 11:05:00 +071.5 1 +072.6 1 +073.0 1 +071.3 1 +071.7 1 +072.2 1 +072.8 1 +075.0 1 +073.0 1 +073.7 1
03-23-2005 11:10:00 +071.5 1 +072.7 1 +073.0 1 +071.4 1 +071.8 1 +072.3 1 +072.9 1 +075.1 1 +073.1 1 +074.0 1
03-23-2005 11:15:00 +071.4 1 +072.7 1 +072.9 1 +071.4 1 +071.6 1 +072.3 1 +072.9 1 +074.9 1 +072.9 1 +073.6 1
03-23-2005 11:20:00 +071.2 1 +072.5 1 +072.5 1 +071.3 1 +071.2 1 +072.0 1 +072.6 1 +074.2 1 +072.4 1 +073.0 1
03-23-2005 11:25:00 +071.1 1 +072.3 1 +072.4 1 +071.1 1 +071.1 1 +071.8 1 +072.5 1 +073.7 1 +072.3 1 +072.7 1
03-23-2005 11:30:00 +071.0 2 +072.2 2 +072.2 2 +071.0 2 +071.1 2 +071.8 2 +072.4 2 +073.4 2 +072.2 2 +072.5 2
03-23-2005 11:35:00 +070.9 2 +072.0 2 +072.1 2 +070.9 2 +071.1 2 +071.7 2 +072.3 2 +073.2 2 +072.2 2 +072.5 2
03-23-2005 11:40:00 +070.8 2 +071.9 2 +072.1 2 +070.8 2 +071.0 2 +071.7 2 +072.2 2 +073.0 2 +072.2 2 +072.4 2
03-23-2005 11:45:00 +070.7 2 +071.8 2 +072.0 2 +070.7 2 +071.0 2 +071.6 2 +072.1 2 +072.9 2 +072.1 2 +072.2 2
03-23-2005 11:50:00 +070.7 2 +071.7 2 +071.9 2 +070.6 2 +070.9 2 +071.5 2 +072.1 2 +072.8 2 +072.0 2 +072.2 2
03-23-2005 11:55:00 +070.6 2 +071.6 2 +071.8 2 +070.5 2 +070.9 2 +071.4 2 +072.0 2 +072.7 2 +072.0 2 +072.1 2
03-23-2005 12:00:00 +070.5 2 +071.5 2 +071.7 2 +070.5 2 +070.8 2 +071.3 2 +071.9 2 +072.6 2 +071.9 2 +072.0 2
03-23-2005 12:05:00 +070.4 2 +071.4 2 +071.6 2 +070.4 2 +070.7 2 +071.3 2 +071.9 2 +072.5 2 +071.9 2 +072.0 2
03-23-2005 12:10:00 +070.3 2 +071.3 2 +071.5 2 +070.3 2 +070.6 2 +071.2 2 +071.8 2 +072.4 2 +071.8 2 +071.9 2
03-23-2005 12:15:00 +070.2 2 +071.2 2 +071.4 2 +070.2 2 +070.5 2 +071.1 2 +071.7 2 +072.3 2 +071.7 2 +071.8 2
03-23-2005 12:20:00 +070.2 2 +071.2 2 +071.3 2 +070.1 2 +070.4 2 +071.0 2 +071.6 2 +072.2 2 +071.6 2 +071.7 2
03-23-2005 12:25:00 +070.1 2 +071.1 2 +071.3 2 +070.1 2 +070.3 2 +071.0 2 +071.6 2 +072.2 2 +071.5 2 +071.6 2
```

Temperature Reading from Probes 1 to N

Alarm Status: 0 No Alarm
1 Alarm, Not Acknowledged
2 Alarm, Acknowledged

SmarTek Systems®
410-315-9727
sales@smarteksys.com
www.smarteksys.com